



CLEAR WATER WASTE DISPOSAL Analytical Results Reporting

E 1995 (R2023-11)

Important Notice: This PDF was designed to be filled in with Adobe Acrobat Reader. Download the form to your desktop and use Adobe Acrobat Reader to open, complete and submit this form. If you are using Edge or Chrome browser some fields will not work as intended and your form may not submit.

Company Name: <input style="width: 90%;" type="text"/>	Contact: <input style="width: 90%;" type="text"/>
Mailing Address: <input style="width: 90%; height: 40px;" type="text"/>	Site Address: <input style="width: 90%; height: 40px;" type="text"/>
GW# (if applicable): <input style="width: 90%;" type="text"/>	BA # (if applicable): <input style="width: 90%;" type="text"/>
Date (YYYY-MM-DD): <input style="width: 90%;" type="text"/>	Reporting Quarter: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4

Please complete and attach with your Laboratory Report

A	B	C	D	
PARAMETERS (Parameters marked by an ★ may be exempt)	BYLAW (14M2012) Discharge Release Limits	LAB RESULTS	Does your Lab Data exceed the limits in Column B? (Yes or No)	
ORGANIC COMPOUNDS				
Benzene	0.5 mg/L		Yes	No
BTEX	1.0 mg/L		Yes	No
Chloroform	0.05 mg/L		Yes	No
Dichlorobenzene (1,2-)	1.0 mg/L		Yes	No
Dichlorobenzene (1,4)	1.0 mg/L		Yes	No
Ethylbenzene	0.5 mg/L		Yes	No
Hexachlorobenzene	0.06 mg/L		Yes	No
Hydrocarbons (As defined by 14M2012)	50 mg/L		Yes	No
Methylene Chloride (dichloromethane)	0.09 mg/L		Yes	No
PCBs (Chlorobiphenyls)	0.004 mg/L		Yes	No
Phenolic Compounds	1.0 mg/L		Yes	No
Tetrachloroethane (1,1,2,2-)	0.06 mg/L		Yes	No
Tetrachloroethylene	0.06 mg/L		Yes	No
Toluene	0.5 mg/L		Yes	No
Trichloroethylene	0.054 mg/L		Yes	No
Xylenes (total)	0.5 mg/L		Yes	No
SALTS				
Cyanide	1.2 mg/L		Yes	No
Chloride	1500 mg/L		Yes	No
Fluoride	10.0 mg/L		Yes	No
Sulphate	1500 mg/L		Yes	No
Sulphides	1.0 mg/L		Yes	No
OTHER				
Flashpoint (Pensky-Martens closed-cup)	<61C		Yes	No
pH	5.5-10.0		Yes	No
Total Chlorine	5 mg/L		Yes	No

Your personal information is being collected for the purposes of administering the Wastewater Bylaw Compliance Program. This information is collected pursuant to Section 33(c) of The Freedom of Information and Protection of Privacy Act of Alberta. If you have any questions about the collection or use of your personal information, please contact the Industrial Monitoring Group Team Lead at Bonnybrook WWTP, 4302 15 St SE, MC#37c, PO Box 2100 Station M, Calgary, AB. T2P 2M5, or by phone at 403-268-4558, or by email at IMG@calgary.ca



CLEAR WATER WASTE DISPOSAL Analytical Results Report

E 1995 (R2023-11) B

A	B	C	D	
PARAMETERS (Parameters marked by an ★ may be exempt)	BYLAW (14M2012) Discharge Release Limits	LAB RESULTS	Does your Lab Data exceed the limits in Column B? (Yes or No)	
SURCHARGE PARAMETERS (Maximum Allowable Limits)				
Biochemical Oxygen Demand (BOD)	300 mg/L		Yes	No
Chemical Oxygen Demand (COD)	600 mg/L		Yes	No
Total Suspended Solids (TSS)	300 mg/L		Yes	No
Oil and Grease (O&G)	100 mg/L		Yes	No
Total Phosphorous (TP)	10 mg/L		Yes	No
Total Kjeldahl Nitrogen (TKN)	50 mg/L		Yes	No
TOTAL METALS (ICP Metal Scan)				
Aluminum	50 mg/L		Yes	No
Antimony	5.0 mg/L		Yes	No
Arsenic	1.0 mg/L		Yes	No
Beryllium	1.0 mg/L		Yes	No
Bismuth	5.0 mg/L		Yes	No
Boron	5.0 mg/L		Yes	No
Cadmium	0.7 mg/L		Yes	No
Chromium	3.0 mg/L		Yes	No
Cobalt	5.0 mg/L		Yes	No
Copper	2.0 mg/L		Yes	No
Iron	50 mg/L		Yes	No
Lead	0.7 mg/L		Yes	No
Manganese	5.0 mg/L		Yes	No
Mercury	0.01 mg/L		Yes	No
Molybdenum	5.0 mg/L		Yes	No
Nickel	2.0 mg/L		Yes	No
Selenium	1.0 mg/L		Yes	No
Silver	0.5 mg/L		Yes	No
Thallium	0.5 mg/L		Yes	No
Tin	5.0 mg/L		Yes	No
Titanium	5.0 mg/L		Yes	No
Vanadium	5.0 mg/L		Yes	No
Zinc	2.0 mg/L		Yes	No

NOTE: If you answered 'YES' in Column D for exceeding any of the Discharge Release Limits listed in Column B, please suspend your discharge to the sanitary sewer and report the situation to the City's Industrial Monitoring Group (IMG) as soon as possible. Contact: IMG Staff at 268-4698 or by email at img@calgary.ca