



RB14-033

FINISHES AROUND URINALS

Reference: Alberta Building Code 2014 Sentence 3.7.2.6.(1)

Sentence 3.7.2.6.(1) "Wall and floor surfaces below the uppermost surfaces of a urinal shall be protected from deterioration by impervious and durable material for a distance from the urinal to a point not less than 900 mm from the projected outline of the urinal on to the wall or floor."

Questions:

- a) Is the horizontal dimension of 900 mm mentioned in the above Article measured from the centre or the edge of the urinal?
- b) Is it the intention of this Article to measure the vertical dimension of 900 mm from the top of the urinal partition?

Commentary | Relevant Facts | Conclusions:

- a) The horizontal dimension of 900 mm shall be measured from the centre of the urinal. This will provide the level of protection intended by the Code.
- b) It is not the intent of the Code to have the impervious finish reach 900 mm above the partition, which itself may reach up to 1500 mm above the floor level, as it would not serve any useful purpose. A more reasonable height for the finish is 1500 mm above the floor level and the Division shall enforce this dimension.

Chief Building Inspector

Regulation Bulletin General Policy Statement

Unless stated otherwise, the Code references in this Regulations Bulletin are to Division B of the Alberta Building Code 2014 (ABC 2014). Regulation Bulletins do not overrule the ABC 2014 nor constitute a relaxation of the Code. They serve to clarify the Code in areas where the latter is ambiguous or does not cover a specific topic. Regulation Bulletins are City of Calgary clarifications for staff use to enable consistency in the application of the Code. Regulation Bulletins should always be read in the context of the appropriate requirements of the Code.