

Electric Vehicle Charging Infrastructure Costing Study

Electrical Engineering Services

Prepared for:

City of Calgary & City of Edmonton

AUTHORED BY:

Jacqueline Cottingham, EIT, B.Sc.(Eng.)

PEER REVIEWED BY:

Brendan McEwen, MCP & Royce Bernard, P. Eng., P.E., RCDD, LEEP AP & Ndumiso Mangena M.SC, P.Eng.

Submitted by:

AES Engineering

505 Burrard Street, Suite 950 - Box91

Vancouver, BC, Canada

V7X1M4

P: 604 569 6500

F: 604 569 6501

aesengr.com

Project No.: 2-21-418 Date: 1/28/2022

DESIGNING A BETTER TOMORROW This report has been reviewed and authorized by Ndumiso Mengena, M.SC, P.Eng.

PROFESSIONAL SEAL



ID#113456 2022-01-28

PERMIT TO PRACTICE AES ENGINEERING LTD.

DATE: Mar. 25 2022

PERMIT NUMBER: P010400

The Association of Professional Engineers and Geoscientists of Alberta (APEGA)

Table of Contents

AB	OUT THIS REPORT	1
SU	MMARY	2
1.	DEFINITIONS	5
2.	BACKGROUND	9
	2.1 EV BENEFITS	9
	2.2 EV ADOPTION TRENDS	9
	2.3 THE NEED FOR ACCESS TO HOME CHARGING	10
	2.4 THE CHALLENGE OF RETROFITTING EV CHARGING IN MULTIFAMILY BUILDINGS	11
	2.5 EV READY REQUIREMENTS	13
	2.6 WHY REQUIRE 100% EV READY PARKING	14
3.	EV CHARGING PERFORMANCE REQUIREMENTS	16
	3.1 IMPLICATIONS FOR EV CHARGING PERFORMANCE REQUIREMENTS	19
4.	EV CHARGING INFRASTRUCTURE COST ANALYSIS	20
	4.1 ABOUT THE ARCHETYPES	20
	4.2 EV READY SCENARIOS	21
	4.2.1 HIGH-RISE	21
	4.2.2 MID-RISE	22
	4.2.3 TOWNHOUSE	22
	4.3 COSTING ANALYSIS FOR NEW DEVELOPMENTS	23
	4.3.1 HIGH-RISE RESIDENTIAL	23
	4.3.2 MID-RISE RESIDENTIAL	24
	4.3.3 TOWNHOUSE	25
	4.4 STRATEGIES TO CONTROL THE COST ASSOCIATED WITH ELECTRICAL SERVICE EXPANSIONS	25
	4.5 COSTING ANALYSIS FOR EXISTING DEVELOPMENTS	26
5.	OPERATING EV CHARGING INFRASTRUCTURE	28
	5.1.1 EVSE COSTS	28
	5.1.2 EV CHARGING SERVICES AND EVEMS COSTS	28
	5.1.3 ELECTRICITY COSTS	29



6. CONCLUSION
7. REFERENCES
APPENDIX A: ARCHETYPE DETAILS AND LOAD CALCULATIONS
APPENDIX B: SINGLE LINE DIAGRAMS
APPENDIX C: PARKING LAYOUT DRAWINGS
APPENDIX D: COSTING ESTIMATES

30

31

APPENDIX E: COST CATEGORIES

About This Report

The City of Calgary and the City of Edmonton commissioned this *Electric Vehicle Charging Infrastructure Costing Study* to inform local governments, developers, electrical designers, utilities, and other stakeholders, about the costs of making parking in new construction EV Ready, and the design strategies that can help minimize these costs. This report provides background information relating to EV Ready requirements; summarizes 100% EV Ready design options and costing analysis for three residential building archetypes common to the City of Calgary and City of Edmonton; and makes recommendations for EV Ready residential parking for the City of Calgary and City of Edmonton's governments.

This report was prepared by AES Engineering Ltd., an electrical engineering firm that has assisted multiple Canadian local governments in developing EV Ready requirements.

Summary

Electric vehicle (EV) adoption is growing rapidly, and near total replacement of passenger vehicles with EVs will be required to achieve local and Federal government climate targets. Providing access to "at home" EV charging is a critical factor to ensure that households will choose EVs. Accordingly, local governments are increasingly requiring 100% "EV Ready" residential parking in new developments. EV Ready parking is defined as a parking stall that has an adjacent energized outlet (i.e. an electrical junction box or a receptacle) at which an EV supply equipment (EVSE – i.e. an EV charger) can be installed in the future.

This *Electric Vehicle Charging Infrastructure Costing Study* summarizes design options and costing analysis for three residential development archetypes typical of the Cities of Calgary's and Edmonton's new construction to comply with 100% EV Ready residential parking requirements. Table ES-1 summarizes the archetypes.

Table ES-1: Overview of parking for each archetype.

				Parking Stalls		
#	Archetype	Storeys	Number of Units	Resident	Visitor	
1	High-Rise	17	334	204	36	
2	Mid-Rise	6	169	169	17	
3	Townhouse	3	16	8	0	

For each archetype, a range of different electrical design scenarios were developed.

For each electrical design, cost estimates were made. Figures ES-1 through ES-3 summarize the cost estimates for the various archetypes' different electrical design scenarios. Costs are broken down into different categories of costs, including metering; communications systems; EV panels and cabling; feeders; and increases to utility service / transformer rating.




Figure ES-1: Cost of EV charging infrastructure for the high-rise archetype in Alberta




Figure ES-2: Cost of EV charging infrastructure for the mid-rise archetype in Alberta




Figure ES-3: Cost of EV charging infrastructure for the townhouse archetype in Alberta

This costing analysis suggests that in the high-rise and mid-rise archetypes, it is possible to implement 100% EV Ready parking for approximately \$1250 to \$1400 per parking space. For the townhouse archetype, parking can be made EV Ready at a cost of approximately \$1700 or less per parking space. These costs represent a small fraction of the cost for a new development to provide onsite parking. Moreover, future-proofing buildings with this EV charging infrastructure will realize significant value for drivers, enabling them to adopt EVs and benefit from their associated savings in total cost of vehicle ownership. The costing analysis indicates that EV charging infrastructure retrofits will be much more costly and complicated than future proofing new construction with 100% EV Ready parking.

It is recommended that municipal governments implement 100% EV Ready requirements for residential parking in new developments.

1. Definitions

This section defines terms related to EV charging infrastructure.

- Electric Vehicle (EV): A vehicle that can plug-in to an external source of electricity (e.g. the electrical grid) to charge an onboard battery that powers the vehicle. EVs include pure battery electric vehicles (BEVs) and plug-in hybrid electric vehicles (PHEVs).
- Electric Vehicle Supply Equipment (EVSE): "A complete assembly consisting of cables, connectors, devices, apparatus, and fittings installed for the purpose of power transfer and information exchange between the branch circuit and the electric vehicle" [1]. Commonly referred to as an EV charging station or EV charger.
- EV Ready Parking Stall: A parking stall that has an adjacent electrical outlet (i.e. a junction box with a cover plate, or a receptacle) at which an EVSE can be installed in the future, as shown in Figure 1. Drivers will install EVSE at EV Ready parking stalls over time, as they adopt EVs.




Figure 1: EV Ready vs EV Charging Parking

• Level 1 (L1) EVSE: An EVSE which supplies alternating current (AC) power, with nominal supply voltage of 120V single-phase power with maximum current of 12A (1.44kW) [2]. The voltage and amperage of L1 EVSE is typical of a regular household outlet. At 1.44kW, a L1 charger can provide approximately 4km to 8km of range per hour, depending on the vehicle.

- Level 2 (L2) EVSE: An EVSE which supplies AC power, with nominal supply voltage of 208V to 240V single-phase power, with maximum current of 80A (19.2kW) [2]. At 6.7kW (a common power output), a L2 charger can provide approximately 25km to 40km of range per hour, depending on the vehicle.
- EV Energy Management System (EVEMS): A system to "monitor electrical loads and to control [EVSE] loads", often by remote means [1]. This includes systems that allow for load sharing (one circuit shared between multiple EVSE) and service monitoring (monitoring the service and controlling EVSE to avoid overloading the service). Figure 2 helps to visualize how EVEMS compare to unmanaged charging configurations. CSA Group has published a research paper on EVEMS, which summarizes the range of EVEMS technologies, for those wishing to better understand these systems [3].




Figure 2: Electrical configurations for visualizing EV charging options

• **Dedicated Circuits:** A configuration of EVSE which includes a dedicated branch circuit to each EVSE, without any load sharing, as depicted in Figure 3. EV charging with dedicated circuits can operate without the use of EVEMS.




Figure 3: Dedicated circuit configuration of EVSE.

• Load Sharing: Sharing one branch circuit between multiple EVSE, with an EVEMS that controls each EVSE such that the total circuit or panel capacity is not exceeded, as depicted in Figure 4. Load calculations to size the feeder and service use the "maximum load allowed by the [EVEMS]" (CSA C22.1-18 Rule 8-106(10)) [1]. Many EVEMS systems enable load sharing across a branch circuit.




Figure 4: Load sharing configuration of EVSE with EVEMS.

• Service Monitoring: An EVEMS that monitors the load on the service or feeder supplying the EVSE and other loads. This may also be referred to as Building Demand Load Management. The EVEMS controls the EVSE such that the maximum capacity of the service or feeder is not exceeded, as depicted in Figure 5. With a correctly configured service monitoring EVEMS, the load for the EVSE "shall not be required to be considered in the determination of the calculated load" (CSA C22.1-18 Rule 8-106(11)) to size the service or feeder [1]. EVEMS with Service Monitoring capability are currently less common than those that facilitate load sharing across a branch circuit; nevertheless, a variety of EV charging service vendors provide EVSE and EVEMS that can perform service monitoring, and service monitoring technology may be more common in the future.




Figure 5: Service monitoring configuration of EVSE with EVEMS.

2. Background

This section provides background information and rationale for EV Ready requirements for new construction.

2.1 EV BENEFITS

EVs realize a variety of benefits for both drivers and broader society, including:

- Cost savings. Future EV drivers will save significantly on the life-cycle costs of their vehicles. The fuel cost to charge an EV at home in Alberta is equivalent to roughly \$0.35 per litre gasoline [4] (exact costs depend on the timing of EV charging under time-of-use or wholesale pricing utility rates, and other factors relating to utility tariffs and vehicle efficiency). Maintenance costs of EVs are half that of gasoline vehicles [5]. Despite EVs currently typically having higher upfront costs than comparable internal combustion vehicles (ICEVs), on a life cycle cost basis, EVs are already typically competitive with ICEVs [6]. And the purchase and lease costs of EVs are declining, making them more and more advantageous [7].
- Improved performance. EVs typically have superior handling. Additionally, EVs are quieter inside, which many drivers report makes for a more enjoyable environment for music and conversation.
- Reduced GHG emissions, better air quality and improved health. EVs' lifecycle Green House Gas (GHG) emissions are about 50% less than fossil fuel vehicles when charging on an electric grid with Alberta's GHG intensity, even accounting for raw material production, manufacturing, use and disposal of vehicles [6]. As Alberta's electric grid decarbonizes into the future, EVs will realize greater life cycle emissions reductions. Moreover, EVs have zero tailpipe emissions, improving the health of our communities. The International Council on Clean Transportation and the Climate & Clean Air Coalition estimate that transitioning onroad transportation to EVs in Canada would avoid 900 deaths each year from tailpipe emissions and save \$7.8 billion in annual healthcare costs [8].

2.2 EV ADOPTION TRENDS

EV adoption is growing exponentially worldwide and is widely forecast to continue to accelerate rapidly over the coming decade and beyond [9] [10]. The cost to produce batteries used in EVs is declining with technology innovation and increased scale of manufacturing. Because of these cost declines, multiple analysts, including the International Council on Clean Transportation and

Bloomberg New Energy Finance, forecast that by the mid-2020s, the cost to produce EVs will be equivalent to internal combustion engine vehicles (ICEVs), and lower cost thereafter [7] [10].

Accordingly, many of the world's largest automakers have announced plans to phase out sales of conventional internal combustion engine vehicles [9] [11]. There is also increasing consumer demand for EVs – A 2021 survey by KPMG suggests that of Canadians planning to purchase an automobile within the next five years, 68% report being likely or very likely to purchase an EV [12].

Public policy is likewise driving EV adoption, with the Government of Canada targeting all sales of passenger vehicles to be zero emissions by 2035 [13]. Achieving local, national, and global climate targets will require the near complete electrification of passenger transportation prior to 2050, 2040 in a best-case scenario.

In summary, despite relatively low levels of adoption of EVs in Alberta in recent years, local governments can confidently expect rapidly growing demand for EVs, and EV charging, in the future. The preponderance of evidence suggests that within 15-20 years, most households will drive an EV, if they have a vehicle.

2.3 THE NEED FOR ACCESS TO HOME CHARGING

The US Department of Energy's "charging pyramid" (see Figure 6) provides a conceptual summary of where passenger vehicle EV charging occurs, including:

- At home. The large majority (currently about 72% in Canada [14] and over 80% in the USA [15]) of passenger EV charging occurs at drivers' home. Access to home charging is a critical factor determining whether households will adopt an EV.
- At work. Approximately 15% of charging occurs at work [14].



Figure 6: Charging Pyramid. Source: US DOE.

- Fleet charging. For vehicles that are part of corporate fleets, almost all charging usually occurs at fleets' "home-base" or depot.
- Public charging. A relatively small proportion of private vehicles' charging occurs at public charging stations. Nevertheless, public charging is important for households without access to home or work charging; to provide "opportunity charging" (i.e. convenient top-up charging when drivers are parked for shopping, recreating, etc.); and to provide for very fast charging on longer trips.

As the upfront costs of EVs continue to decline, access to convenient forms of charging will increasingly become the most important factor determining EV adoption. As home charging is widely recognized as the most convenient form of EV charging, improving access to home charging is particularly important to enabling EV adoption.

2.4 THE CHALLENGE OF RETROFITTING EV CHARGING IN MULTIFAMILY BUILDINGS

For single family homes with their own private onsite parking space (e.g. a garage or parking pad), implementing "at home" EV charging is usually relatively simple and low cost. However, retrofitting EV charging into multifamily buildings is much more complicated and costly. Broadly, multifamily buildings that are not constructed with EV Ready infrastructure can pursue one of two strategies to implement EV charging:

- 1. Comprehensive EV Ready retrofits. A building undertakes an electrical renovation to make all parking EV Ready. As drivers adopt EVs, EVSE are installed at their assigned parking space.
- 2. Incremental additions of EV chargers. A building implements a few chargers at a time. Often, EVSE are located in common parking areas (e.g. visitor parking). Over time, as more EVs are adopted by residents, additional EVSE will need to be added.

Table I compares these two models for providing EV charging in existing multifamily buildings that have not been future-proofed in new construction for EV charging. Table I makes clear that there are significant challenges to retrofitting multifamily buildings to provide EV charging. Comprehensive 100% EV Ready retrofits often provide the greatest value over the life cycle of the building but are complicated and entail greater costs than future-proofing new construction. To avoid perpetuating the challenge of providing EV charging infrastructure in multifamily buildings, Canadian local governments are increasingly adopting 100% EV Ready residential parking requirements for new construction.

Table 1: Comprehensive EV Ready retrofits vs. incremental EVSE additions

	Comprehensive 100% EV Ready retrofits	Incremental additions of EVSE
Life-Cycle Cost Per Parking Space	Less expensive, especially when designed with appropriate levels of load sharing and EVEMS.	Much more expensive over time, assuming that all vehicles in multifamily buildings will ultimately be EVs.
Process	One-time significant electrical renovation.	Repeated electrical renovations.
Location of charging stations	In drivers' assigned parking space.	Often initially in commonly accessible parking (e.g. visitor parking). Sometimes in assigned parking.
Process for drivers to install chargers	Simple (after initial comprehensive electrical renovation).	Typically lengthy and complicated.
Convenience	Highly convenient for drivers, EV charging in regular assigned parking spot.	Inconvenient for drivers when chargers are located in commonly accessible parking (e.g. visitor parking)
Futureproofing	With EVEMS, frequently can ensure sufficient electrical capacity for all parking spaces to have EV charging.	Initial installations may not leave room for later expansion; potential for stranded assets. Potential to exhaust limited electrical capacity if design for EVEMS not considered.
Market adoption	Currently very uncommon, incentives are increasing adoption by offsetting the high upfront cost.	Typical approach to adding EV charging in existing multifamily buildings.
Electrical Permit	Typically, only a single electrical permit is required.	New electrical permits will be required for each electrical renovation.

2.5 EV READY REQUIREMENTS

Cities and other jurisdictions are increasingly focused on ensuring that their residents have access to convenient forms of EV charging. Table 2 summarizes EV Ready requirements adopted by a selection of Canadian cities. Other Canadian cities are understood to be considering similar requirements.

Table 2: EV Ready parking requirements in select Canadian jurisdictions (list of jurisdictions is not intended to be comprehensive).

5	EV Ready Parking Requirements				
Jurisdiction	Residential	Commercial			
City of Toronto, ON	100%	25%			
City of Vancouver, BC	100%	10%			
City of Port Moody, BC	100%	20%			
City of Surrey, BC	100%	20%			
City of Victoria, BC	100%	~5% (varies by land use)			
District of Saanich, BC	100%	~5% (varies by land use)			
City of Richmond, BC	100%				
City of Burnaby, BC	100%				
City of New Westminster, BC	100%				
City of North Vancouver, BC	100%				
District of West Vancouver, BC	100%				
District of North Vancouver. BC	100%				
Town of View Royal, BC	100%				
Township of Langley. BC	1 per dwelling unit				
City of Nelson. BC	1 per dwelling unit	10%			
City of Coquitlam, BC	1 per dwelling unit				
City of Laval, QC	50% in multifamily buildings				
Province of Quebec	All single family dwelling parking				

Local governments with 100% EV Ready requirements have allowed new developments to design for use of EVEMS, reducing the cost of implementing 100% EV Ready parking.

2.6 WHY REQUIRE 100% EV READY PARKING

AES typically recommends jurisdictions adopt 100% EV Ready residential parking requirements. Benefits of EV Ready parking requirements include:

- Consistency with local and national GHG and EV sales targets. The Government of Canada
 has adopted targets for 100% of passenger vehicle sales to be zero emissions by 2035. This is
 well within the lifetime of new residential buildings that would be subject to EV Ready
 requirements.
- Equity between residents. Requirements for 100% "EV Ready" parking stalls provide all
 residences with equitable access to an outlet that provides adequate electrical capacity for
 EV charging, and avoids challenges associated with trading parking spaces or renovating for
 EV access.

If instead, only a portion of parking spaces are made "EV Ready", households without access to such an "EV Ready" space would either need to 1) renovate electrical systems to provide access to EV charging, or 2) trade parking spaces with households that have an EV Ready space.

Trading parking spaces is typically challenging or not possible in condominiums. Different forms of parking tenure in condominiums have different implications for trading parking stalls; however, all present major difficulties for residents of condominiums to trade parking stalls. This is widely recognized by those in the EV charging industry as an impediment to EV adoption.

As noted in section 2.4, retrofitting parking to provide EV charging is costly and complicated. In practice, the challenges associated with trading and/or renovating stalls typically prevent EV uptake in Multi-Unit Residential Buildings (MURBs).

- Simple enforcement. Compared to other ways that jurisdictions have structured EV charging infrastructure requirements for new developments, 100% EV Ready requirements are relatively simple for local governments to enforce.
 - Some jurisdictions (e.g. California) have required that new developments provide sufficient electrical capacity on electric panels to provide for future EV charging, but do not require wiring an electrical outlet. However, local building officials, transportation, and/or development approvals staff typically do not possess the requisite experience or qualifications to review electrical plans and calculations. EV Ready requirements necessitates

checking for the provision of an electrical outlet, a much simpler task for personnel without electrical background.

• Reasonable cost. As explored below, 100% EV Ready parking can be implemented in new construction at reasonable costs.

3. EV Charging Performance Requirements

To ensure that drivers can receive sufficient charge from EV charging systems, cities' EV Ready requirements typically reference minimum "charging performance requirements". These charging performance requirements limit the amount of load sharing allowed between EVs. This is intended to ensure that EVs receive an adequate amount of energy to meet drivers' needs.

Appropriate charging performance requirements vary between different geographic areas, based on factors including:

- Daily driving distance. Average vehicle kilometers travelled (VKT) per day varies significantly
 across and between regions. Generally, vehicles in more suburban or exurban locations will
 travel farther than in central cities, and thus will require more energy to charge.
- The efficiency of the region's vehicle fleet.
- Temperature extremes, which can reduce vehicles' efficiency.
- Available charging time.
- Charging efficiencies.
- Other factors.

AES has developed a model to determine appropriate charging performance requirements for different geographic regions, which was applied to the City of Calgary and the City of Edmonton (the Cities). In brief, the model used: VKT data from the Cities; weather data; information about passenger vehicle fleet composition; and reasonable assumptions about resident driving patterns, including arrival and departure times, and the number of vehicles not driving on a given day. The VKT data used for the Cities is only valid for residential buildings within the city limits of Calgary and Edmonton, respectively. The model assumes that almost all EV charging occurs at home, with very limited use of public or workplace charging; of course, vehicles on long trips that extend beyond their range would need additional charging.

The model determines the maximum number of vehicles that may load share across a circuit of a given electrical power capacity, while ensuring that there are no more than:

- 10% of days when vehicles are not fully charged overnight.
- 1% of days when vehicles cannot complete the next day's driving. On those 1% of days, drivers
 would need to augment home charging with visiting a public charging station, workplace
 charging, etc.

Table 3 summarizes recommended performance requirements determined by the model, organized by average daily weekday vehicle VKT in the City of Calgary. For this study, the City of Calgary reported average daily vehicle VKT per vehicle is 27.7km.

Table 3: Summary of performance requirements in terms of the maximum amount of sharing recommended on each circuit size for different mean VKT In the City of Calgary.

Circuit Breaker	Maximum number of EVs (by mean daily weekday VKT)					
Size	35km or less	40km	45km	50km		
20A	7					
30A	7	1	1	1		
40A	4	3	3	2		
50A	5	4	4	3		
60A	7	6	5	4		
70A	8	7	6	5		
80A	10	8	7	6		
100A	12	11	9	8		
125A	15	14	12	11		

Table 4 summarizes recommended performance requirements determined by the model, organized by average daily weekday vehicle VKT in the City of Edmonton. For this study, the City of Edmonton reported average daily vehicle VKT per vehicle is 31.4km.

Table 4: Summary of performance requirements in terms of the maximum amount of sharing recommended on each circuit size for different mean VKT in the City of Edmonton

Circuit Breaker	Maximum number of EVs (by mean daily weekday VKT)					
Size	35km or less	40km	45km	50km		
20A	1					
30A	1	1	1	1		
40A	4	3	3	2		
50A	5	4	3	3		
60A	6	5	4	4		
70A	8	6	5	5		
A08	10	8	7	6		
100A	12	10	9	7		
125A	15	13	11	10		

AES recommends that jurisdictions not adopt performance requirements for new construction that allow for higher levels of load sharing than are presented for jurisdictions with VKT of 30km in Table 3 above. The rationale for such a minimum baseline performance standard for all communities is that:

- Some vehicles may not accept less than 8A.
- It is anticipated prospective EV drivers will have expectations for speed of charging and quality of service that greater degrees of load management will not meet.
- EV charging service providers have indicated hesitancy to service buildings with greater levels of load sharing, which may limit availability of EVEMS systems for buildings designed for higher levels of load management.

- Average VKTs may increase in the future. The introduction of greater use of ride-hailing and car-sharing, and reduction in the number of parking spaces in new developments and associated decline in car ownership, may increase average VKTs.
- The growing tendency for larger vehicles in Canada may decrease future fleet efficiencies.

3.1 IMPLICATIONS FOR EV CHARGING PERFORMANCE REQUIREMENTS

AES's model suggests 4-share on a 40A circuit is sufficient for communities with daily average VKTs of 35km or less, which includes the Cities of Calgary and Edmonton. For this study, the City of Calgary reported average daily vehicle VKT per vehicle is 27.7km, Edmonton reported 31.4km.

More suburban communities, near Calgary or Edmonton, with longer VKTs could consider adopting more stringent performance requirements in accordance with their communities' average VKT values in Table 3 and Table 4, if they are proximal to Calgary or Edmonton, respectively. However, this study does not provide sufficient information or data to inform the EV Ready requirements for cities outside of Calgary and Edmonton. The VKT data used to inform this study was only for residence's withing the city boundaries of Calgary and Edmonton.

Less stringent performance requirements would not provide for full reliance on home charging. Adopting less stringent performance requirements would effectively require that some drivers augment home charging with workplace charging or public charging, and/or that daily driving distances decline in the future.

4. EV Charging Infrastructure Cost Analysis

This section reviews analysis of the electrical designs and associated costs of providing EV Ready parking in three residential building archetypes common to the Cities of Calgary and Edmonton. For each archetype, a range of different electrical design scenarios were developed. The scenarios' electrical designs included different load sharing strategies, as well as service monitoring strategies.

Costs for each scenario were estimated, relative to a baseline development with no EV charging infrastructure. Additionally, the cost of implementing the same electrical systems in a retrofit context were estimated; this analysis is intended to serve as a rough estimate of the cost of retrofitting buildings to feature EV charging infrastructure.

There is no increased permitting cost for EV charging infrastructure in new construction in the City of Calgary or the City of Edmonton [16] [17]. All new buildings require an electrical permit and therefore this is not an increased cost over the baseline development previously mentioned.

This costing analysis does not include the purchase or installation cost of EVSE or ongoing fees for EVEMS, as these costs are not expected to be required to be borne by building developer. However, a brief discussion of these costs is provided in Section 5.4.

Details of the electrical designs for different scenarios and of the costing analysis are provided in Appendices as follows:

- Appendix A: Archetype details and load calculations.
- Appendix B: Single line diagrams.
- Appendix C: Parking layout drawings.
- Appendix D: Costing estimates.
- Appendix E: Cost categories.

4.1 ABOUT THE ARCHETYPES

Three residential development archetypes were assessed: A high-rise residential development, a mid-rise residential development, and a townhouse development. These building archetypes are common in the Calgary and Edmonton areas and were derived from actual development applications in the City of Calgary. A summary of the archetypes is provided in Table 5. EV Ready parking was designed for resident parking only, and not visitor parking stalls.

Table 5. Overview of parking for each archetype.

				Parking Stalls		
#	Archetype	Storeys	Number of Units	Resident	Visitor	
1	High-Rise	17	334	204	36	
2	Mid-Rise	6	169	169	17	
3	Townhouse	3	16	8	0	

4.2 EV READY SCENARIOS

The sub-sections below summarize the different electrical design configurations and associated EVEMS control schemes for the development archetypes.

4.2.1 High-Rise

Table summarizes the EV Ready configuration scenarios considered for the high-rise development, including:

- C1 features dedicated 40A circuits to each parking space.
- C2 features 4-share on 40A circuits.
- C3 features 10-share on 80A circuits.
- C4 features 4-share on 40A circuits with service monitoring.

Table 6: High-rise scenarios summary.

#	Electrical configuration description	% Residential Parking that is EV Ready	Nominal EVSE Power (kW)	EV Ready Spaces per Branch Circuit	Circuit Breaker Rating (A)	Max Current (A)
C1	Dedicated 40A circuit	100%	6.7	1	40	32
C2	4-share on 40A	100%	6.7	4	40	32
С3	10-share on 80A	100%	6.7	10	80	64
C4	4-share on 40A with service monitoring	100%	6.7	4	40	32

4.2.2 Mid-Rise

Table summarizes the EV Ready configuration scenarios considered for the mid-rise development:

- C1 features dedicated 40A circuits to each parking space.
- C2 features 4-share on 40A circuits.
- C3 features 10-share on 80A circuits.

Table 7: Mid-rise scenarios summary.

#	Electrical configuration description	% Residential Parking that is EV Ready	Nominal EVSE Power (kW)	EV Ready Spaces per Branch Circuit	Circuit Breaker Rating (A)	Max Current (A)
CI	Dedicated 40A circuit	100%	6.7	1	40	32
C2	4-share on 40A	100%	6.7	4	40	32
С3	10-share on 80A	100%	6.7	10	80	64

4.2.3 Townhouse

Table summarizes the EV Ready configuration scenarios considered for the townhouse development:

- C1 features dedicated 40A circuits to each parking space.
- C2 features 4-share on 40A circuits.
- C3 features 8-share on 70A circuit to each garage

Table 8: Townhouse scenarios summary.

#	Electrical configuration description	% Residential Parking that is EV Ready	Nominal EVSE Power (kW)	EV Ready Spaces per Branch Circuit	Circuit Breaker Rating (A)	Max Current (A)
C1	Dedicated 40A circuit	100%	6.7	1	40	32
C2	4-share on 40A	100%	6.7	4	40	32
С3	8-share on 70A	100%	6.7	8	70	32

The townhouse archetype used for this study features a shared carport for the residential parking stalls. This design is understood to be more common in the townhouses being developed in Calgary

and Edmonton. The shared carport layout allows for more efficient EV load sharing than in designs where each unit has a garage. This is because load sharing between garages is not practical, nor allowed under Canadian Electrical Code (CEC) rule 26-564(a) [1].

4.3 COSTING ANALYSIS FOR NEW DEVELOPMENTS

This section summarizes the results of the costing analysis for the three archetypes. This costing analysis is specific to construction in Alberta, using RSMeans data for the Calgary and Edmonton market.

4.3.1 High-Rise Residential

Figure 7 summarizes the estimated costs per EV Ready parking space for the high-rise archetype. Costs are broken down into different categories of costs, including metering; communications systems; EV panels and cabling; feeders; and increases to utility service / transformer rating. The systems included in these categories are further summarized in Appendix E.




Figure 7 Cost of EV charging infrastructure for the high-rise archetype

4.3.2 Mid-Rise Residential

Figure 8 summarizes the estimated costs for EV Ready infrastructure per stall in the mid-rise archetype.




Figure 8 Cost of EV charging infrastructure for the mid-rise archetype

4.3.3 Townhouse

Figure 9 shows the cost per parking space for EV Ready parking for the townhouse archetype for new developments.




Figure 9 Cost of EV charging infrastructure for the townhouse archetype

4.4 STRATEGIES TO CONTROL THE COST ASSOCIATED WITH ELECTRICAL SERVICE EXPANSIONS

This study includes cost estimates to increase service sizes and transformer ratings. However, the costs charged to new developments that upgrade service sizes can vary substantially, depending on the nature of electric utility works that will be required to provide electrical service of the necessary capacity to the site.

Electrical service expansion costs can differ substantially between different development sites, depending on the nature of the capital works that a distribution utility would need to take to provide service to a site. It is possible that EV charging infrastructure can increase the required capacity of the electrical service that a development would otherwise feature, and that in some instances this can result in relatively large increases in developments' capital contribution. In these instances, developers and designers are recommended to consider designing for the use of service monitoring,

to avoid needing to increase the capacity of developments' service; in turn, this design strategy can avoid incurring the costs associated with a larger service size.

4.5 COSTING ANALYSIS FOR EXISTING DEVELOPMENTS

This section provides a rough estimate of the cost to implement EV Ready parking in a retrofit context, if new construction were not made 100% EV Ready. As noted in section 2.4, it is considerably more complicated and costly to implement EV charging infrastructure in a retrofit context, as opposed to making new construction EV Ready. Costs per parking space for comprehensive 100% EV Ready retrofits will typically be less per parking space than if done incrementally, in AES's experience, but still considerably more than future-proofing new construction to be 100% EV Ready.

The following figures represent estimates to compare the cost of 100% EV Ready parking in new construction to the cost of incremental additions of EV Ready parking, as described in section 2.4. Figure 10, 11, and Figure 12, outline the costs for high-rise, mid-rise, and townhouse, respectively. Estimates were made by assigning a cost multiplier for each component of the electrical system. See Appendix D for details of these cost estimates.





Figure 10 Comparison of cost per energized parking stall of EV charging infrastructure for new and existing developments for the high-rise archetype



11 Comparison of cost per energized parking stall of EV charging infrastructure for new and existing developments for the mid-rise archetype




Figure 12 Comparison of cost per unit of EV charging infrastructure for new and existing developments for the townhouse archetype

5. Operating EV Charging Infrastructure

This study focuses on the cost of EV Ready infrastructure for new developments. It does not forecast operating costs for use of this infrastructure. This section provides commentary on the costs to end users of EVSE; EV charging services, including EVEMS; and electricity.

5.1.1 EVSE Costs

The cost of residential level 2 EVSE varies depending on the power level, built-in load sharing, and whether the EVSE can communicate over some network for the purposes of EV energy management and other services (i.e. "smart charging station"). In AES's experience, installed costs for 7.2kW smart EVSE with appropriate for residential applications range from approximately \$1000 to \$2000+, depending on the vendor.

Developments with dedicated circuits could use "dumb" EVSE without network connectivity. These EVSE are typically lower cost (e.g. \$300 to \$1000+). However, use of dumb EVSE may entail higher ongoing utility costs, due to higher demand charges, and inability to respond to utility price signals.

5.1.2 EV Charging Services and EVEMS Costs

In EV charging configurations that use EVEMS, EV charging service providers will typically be engaged by multifamily buildings. They will provide EVSE, EVEMS, and services such as billing drivers for electricity costs, reporting usage data, and customer assistance.

Many EVEMS systems currently rely on subscription fees charged on a per station basis. If system communications are achieved via cellular networks, this also includes a network fee. Experience at AES Engineering indicates subscription fees for EVEMS and billing management systems are approximately \$240 per station per year, including network fees. RMI estimates network fees to be between \$200 USD and \$250 USD per station per year, with additional maintenance contracts which could cost \$575 USD per charger per year, but which vary widely depending on site specific parameters [18]. Subscription fees can significantly increase operating costs of charging stations. Systems and business models that entail reduced or no subscription fees may increase in the future.

When selecting an EV charging service provider, the design should consider the communication method used by the provider. Many providers use cellular networks for communication because of the reliability and availability. Each building should be considered on a case-by-case basis and factors to consider include:

- Ease of installation.
- Future-proof solution.
- Reliable network.

Availability of connectivity in the specific location (eg. Indoor vs outdoor applications).

5.1.3 Electricity Costs

As noted in section 2.1, the electricity costs for passenger EVs will be well below fossil fuel costs under a wide range of assumptions. The costs for electricity will depend on the rate charged (e.g. residential rates; commercial rates; special EV charging rates that may emerge in the future). Building owners and condominium will typically adopt user fees for EV drivers, recovering the cost of electricity paid to utilities from drivers. Figure 13 illustrates a common process, whereby EV owners repay the costs of electricity paid by the condomium, by means of an EV network service provider.




Figure 13 Payment structure for EV charging in condominiums with networked EVEMS

6. Conclusion

Local governments are increasingly requiring 100% of residential parking in new developments to be EV Ready. This report provides relevant context, background information, and summarizes design and costing analysis for three residential building archetypes common to Calgary and Edmonton.

This costing analysis suggests that in the high-rise and mid-rise archetypes, it is possible to implement 100% EV Ready parking for approximately \$1250 to \$1400 per parking space. For the townhouse archetype, parking can be made EV Ready at a cost of approximately \$1700 or less per parking space. These costs represent a small fraction of the cost for a new development to provide onsite parking. Moreover, future-proofing buildings with this EV charging infrastructure will realize significant value for drivers, enabling them to adopt EVs and benefit from their associated savings in total cost of vehicle ownership. The costing analysis indicates that EV charging infrastructure retrofits will be much more costly and complicated than future proofing new construction with 100% EV Ready parking.

It is recommended that local governments implement 100% EV Ready requirements for residential parking in new developments.

7. References

- [1] Canadian Standards Association, "Canadian Electrical Code, Part 1," Canadian Standards Association, Toronto, 2018, p. Section 8, Section 26.
- [2] SAE International, "SAE Electric Vehicle and Plug in Hybrid Electric Vehicle Conductive Charge Coupler," SAE International, 2017.
- [3] K. C. M. S.-z. Clay Howey, "Electric Vehicle Energy Management Systems," CSA Group, 2019.
- [4] Ontario Cars, "How Much Does It Cost To Charge An Electric Vehicle," 15 May 2020. [Online]. Available: https://www.blog.ontariocars.ca/how-much-does-it-cost-to-charge-an-electric-vehicle/.
- [5] Consumer Reports, "Electric Vehicle Ownership Costs," 2020.
- [6] MIT Trancik Lab, "carboncounter," [Online]. Available: carboncounter.com.
- [7] International Council on Clean Transportation, "Upate on Electric Vehicle Costs in the United States through 2030," 2019.
- [8] International Council on Clean Transportation and Climate & Clean Air Coalition, "A Global Snapshot of the Air Pollution-Related Health Impacts of Transportation Sector Emissions in 2010 and 2015," 2019.
- [9] International Energy Agency, "Global EV Outlook," 2021.
- [10] I. Boudway, "Batteries For Electric Cars Speed Toward a Tipping Point," Bloomberg, 16 December 2020. [Online]. Available: https://www.bloomberg.com/news/articles/2020-12-16/electric-cars-are-about-to-be-as-cheap-as-gas-powered-models. [Accessed 7 January 2021].
- [11] A. White, "Here Are All the Promises Automakers Have Made about Electric Cars," Car and Driver, 21 February 2021. [Online]. Available: https://www.caranddriver.com/news/g35562831/ev-plans-automakers-timeline/.
- [12] KPMG LLP, "The next new vehicle purchase for nearly 70 per cent of Canadians will be an electric model: KPMG in Canada survey," Cision, 21 February 2021. [Online]. Available:

- https://www.newswire.ca/news-releases/the-next-new-vehicle-purchase-for-nearly-70-per-cent-of-canadians-will-be-an-electric-model-kpmg-in-canada-survey-889637501.html.
- [13] Transport Canada, "Zero-emission vehicles," Government of Canada, 31 January 2020. [Online]. Available: https://tc.canada.ca/en/road-transportation/innovative-technologies/zero-emission-vehicles. [Accessed 7 January 2021].
- [14] Fleetcarma, "Charge the North: Results from the world's largest EV charging study," 2020.
- [15] US Department of Energy, "Charging at Home," [Online]. Available: https://www.energy.gov/eere/electricvehicles/charging-home.
- [16] City of Calgary, "Electrical permits for contractors," [Online]. Available: https://www.calgary.ca/pda/pd/permits/building-permits/electrical-permits.html. [Accessed December 2021].
- [17] City of Edmonton, "Electrical Commercial Permits & Inspections," [Online]. Available: https://www.edmonton.ca/business_economy/commercial-electrical-permits. [Accessed December 2021].
- [18] C. Nelder and E. Rogers, "Reducing EV Charging Infrastructure Costs," 2019. [Online]. Available: https://rmi.org/wp-content/uploads/2020/01/RMI-EV-Charging-Infrastructure-Costs.pdf. [Accessed 7 July 2020].
- [19] BC Hydro, "General Service Business Rates," BC Hydro, 2020. [Online]. Available: https://app.bchydro.com/accounts-billing/rates-energy-use/electricity-rates/business-rates.html. [Accessed 7 July 2020].
- [20] DCC, "Electric Vehicle Energy Management System," DCC, 2020. [Online]. Available: https://dccelectric.com/. [Accessed 25 August 2020].
- [21] VariableGrid, "VariableGrid," VariableGrid, 2020. [Online]. Available: https://www.variablegrid.net. [Accessed 19 August 2020].
- [22] AES Engineering, "Electric Vehicle Charging Infrastructure in Shared Parking Areas: Resources to Support Implementation and Charging Infrastructure Requirements," [Online]. Available: https://www.bchydro.com/content/dam/BCHydro/customer-portal/documents/power-

- smart/electric-vehicles/ev-charging-infrastructure-in-shared-parking-areas.pdf. [Accessed 25 August 2020].
- [23] AES Engineering Ltd., "Electric Vehicle Charging Infrastructure in New Multifamily Developments- Requirement Options and Costing Analysis," 4 April 2017. [Online]. Available: https://udi.bc.ca/wp-content/uploads/2017/06/Final-Report-r004-EV-Requirements-20170404.pdf. [Accessed 7 January 2021].

Appendix A: Archetype details and load calculations	

LOAD CALCULATION SUMMARY

	BASELINE (KW)	CONFIGURATION	EV CHARGING (KW)	TOTAL (KW)
		C1 - Dedicated circuits on 40A, 100% EV Ready	1,364	3,729
ARCHETYPE 1:		C2 - 4-share on 40A, 100% EV Ready	346	2,710
HIGH-RISE	2,364	C3 - 10-share on 80A, 100% EV Ready	266	2,630
MIXED USE		C4 - 4-share on 40A, 100% EV Ready with service monitoring	0*	2,710
ARCHETYPE 2:		C1 - Dedicated circuits on 40A, 100% EV Ready	1,125	2,647
MID-RISE	1,808	C2 - 4-share on 40A, 100% EV Ready	286	1,808
MULTIFAMILY		C3 - 10-share on 80A, 100% EV Ready	226	1,748
ADCHETVDE 2.		C1 - Dedicated circuits on 40A, 100% EV Ready	53	186
ARCHETYPE 3: TOWNHOUSE	133	C2 - 4-share on 40A, 100% EV Ready	13	144
TOWNTIOUSE		C3 - 8-share on 70A, 1000% EV Ready	12	144

^{*}EVEMS will regulate supply to EVSEs based on building usage to stay within the capacity of electrical equipment

ARCHETYPE 1: HIGH-RISE MIXED USE

GENERAL			
Space heating	electric		
Range	electric		
Air-conditioning	all suites		

AREAS				
TYPE	ft ²	m²		
Suites	189,390	17,595		
Parking	104,711	9,728		
Retail	11,403	1,059		
Base building	12,303	1,143		
TOTAL	317,807	29,525		

EQUIPMENT SPECIFICATION					
TYPE LOAD (HP) QTY EFFICIENCY					
High Rise Elevators 75 4					
Fire Pump 100 1 75%					

SUITES					
TYPE	No. AREA				
TIPE	IVO.	ft ²	m ²	TOTAL (m²)	
Unit A	28	630	59	1,639	
Unit B	28	522	48	1,358	
Unit C	104	744	69	7,188	
Unit D	52	489	45	2,362	
Unit E	34	589	55	1,860	
Unit F	84	396	37	3,090	
Unit G	2	520	48	97	
TOTAL	332			17,595	

SUITE LOADS (KW)							
TYPE	FIRST 45m ²	NEXT 45m ²	NEXT 90m ²	NEXT 90m ²	RANGE	DRYER @ 25%	LOAD (KW)
Unit A	3.5	1.5	0.0	0	6	1.25	12.3
Unit B	3.5	1.5	0.0	0	6	1.25	12.3
Unit C	3.5	1.5	0.0	0	6	1.25	12.3
Unit D	3.5	1.5	0.0	0	6	1.25	12.3
Unit E	3.5	1.5	0.0	0	6	1.25	12.3
Unit F	3.5	0.0	0.0	0	6	1.25	10.8
Unit G	3.5	1.5	0.0	0	6	1.25	12.3

RESIDENTIAL			
ITEM	LOAD (KW)		
first suite @ 100%	12.3		
2 nd & 3 rd @ 65%	15.9		
4 th & 5 th @ 40%	9.8		
6 th - 20 th @25%	45.9		
remainder @10%	382.2		
electric heating	735.6		
TOTAL	1,202		

RETAIL			
ITEM	W/m ²	LOAD (KW)	
Basic allowance	30	31.8	
Mechanical	55	58.3	
electric heating	56	46.6	
TOTAL	136.6		

EQUIPMENT				
ITFM	DEMAND	LOAD (KW)		
	FACTOR	LOAD (KW)		
High Rise Elevators	50%	149.1		
Fire Pump	100%	99.4		
TOTAL		248.6		

BASE BUILDING			
ITEM	LOAD (KW)		
Basic allowance	98.7		
Mechanical	266.0		
Electric heating	412.4		
TOTAL	777.1		

PARKING STALLS		
TYPE	TOTAL	
Resident	204	
Visitor	36	
TOTAL	240	

EV CHARGING AND TOTAL LOAD						
OPTION	TOTAL EV- READY CCT	DEMA ND	TOTAL EV CHARGING POWER (KW)	TOTAL BUILDING LOAD (KW)		
	BUILDING ON	LY				
Building only	Building only 2,364					
RESIDENT	TAL EV CHARGI	NG OPT	IONS			
C1. Dedicated circuits on 40A, 100% EV Ready	3,729					
C2. 4-share on 40A, 100% EV Ready	52	100%	346	2,710		
C3. 10-share on 80A, 100% EV Ready	21	100%	266	2,630		
C4. 4-share on 40A, 100% EV Ready with serv	52	100%	346	2,710		

ARCHETYPE 2: MID-RISE MULTIFAMILY

GENERAL			
Space heating	electric		
Range	electric		
Air-conditioning	all suites		

AREAS					
TYPE ft ² m ²					
Suites	124,056	11,525			
Parking	69,692	6,475			
Base building	893	83			
Retail	22,653	2,105			
TOTAL	194.641	18.083			

EQUIPMENT SPECIFICATION				
TYPE LOAD (HP) QTY EFFICIENCY				
Mid Rise Elevators	75	3	75%	
Fire Pump	50		75%	

SUITES					
TYPE	No.	AREA			
TIPE	IVO.	ft²	ft ² m ²		
Micro 1 Bed	28	520	48	1,353	
1 Bed + Den	46	646	60	2,761	
Micro 2 Bed	19	780	72	1,377	
2 Bed + Den	72	850	79	5,686	
3 Bed	4	940	87	349	
TOTAL	169			11,525	

SUITE LOADS (KW)							
TYPE	FIRST 45m ²	NEXT 45m ²	NEXT 90m ²	NEXT 90m ²	RANGE	DRYER @ 25%	LOAD (KW)
Micro 1 Bed	3.5	1.5	0.0	0	6	1.25	12.3
1 Bed + Den	3.5	1.5	0.0	0	6	1.25	12.3
Micro 2 Bed	3.5	1.5	0.0	0	6	1.25	12.3
2 Bed + Den	3.5	1.5	0.0	0	6	1.25	12.3
3 Bed	3.5	1.5	0.0	0	6	1.25	12.3

RESIDENTIAL			
ITEM	LOAD (KW)		
first suite @ 100%	12.3		
2 nd & 3 rd @ 65%	15.9		
4 th & 5 th @ 40%	9.8		
6 th - 20 th @25%	45.9		
remainder @10%	182.5		
Electric Heating	482.7		
TOTAL	749		

RETAIL				
ITEM	W/m ²	LOAD (KW)		
Basic allowance	30	63.1		
Mechanical	55	115.7		
Electric Heating	56	87.7		
TOTAL	266.6			

EQUIPMENT				
ITEM DEMAND FACTOR LOA				
Elevators	50%	111.9		
Fire Pump	100%	0.0		
TOTAL		111.9		

BASE BUILDING			
ITEM	LOAD (KW)		
Basic allowance	44.7		
Mechanical	131.9		
Electric Heating	217.7		
TOTAL	394.3		

PARKING STALLS		
TYPE	TOTAL	
Resident	169	
Visitor	17	
TOTAL	186	

EV CHARGING AND TOTAL LOAD						
OPTION	TOTAL EV- READY CCT	DEMA ND	TOTAL EV CHARGING POWER (KW)	TOTAL BUILDING LOAD (KW)		
BUILDING ONLY						
Building Only — 1,522						
RESIDENTIAL EV CHARGING OPTIONS						
C1. Dedicated circuits on 40A, 100% EV Read	169	100%	1,125	2,647		
C2. 4-share on 40A, 100% EV Ready	43	100%	286	1,808		
C3. 10-share on 80A, 100% EV Ready	17	100%	226	1,748		

ARCHETYPE 3: TOWNHOUSE

GEN	IERAL
Space heating	electric
Range	electric
Air-conditioning	all suites

AREAS						
TYPE	ft ²	m²				
Townhomes	13,562	1,260				
TOTAL	13,562	1,260				

UNITS						
TYPE	No.					
TIPE	IVO.	ft ²	m²	TOTAL (m²)		
Micro Suite	8	484	45	360		
3 Bed, 2 Stories	6	1,292	120	720		
3 Bed	2	969	90	180		
	16			1,260		


UNIT LOADS (KW)							
TYPE FIRST 90m ² NEXT 90m ² NEXT 90m ² NEXT 90m ² RANGE DRYER @ 25% LOAD (KW)							
Micro Suite	5.0	0.0	0.0	0.0	6	1.25	12.3
3 Bed, 2 stories	5.0	1.0	0.0	0.0	6	1.25	13.3
3 Bed, 2 stories	5.0	0.0	0.0	0.0	6	1.25	12.3

RESIDENTIAL					
ITEM	LOAD (KW)				
first suite @ 100%	13.3				
2 nd & 3 rd @ 65%	17.2				
4 th & 5 th @ 40%	10.6				
6 th - 20 th @25%	36.4				
remainder @10%	0.0				
electric heating	55.0				
TOTAL	132.5				

PARKING STALLS				
TYPE	TOTAL			
Resident	8			
Visitor	0			
TOTAL	8			

EV CHARGING AND TOTAL LOAD						
OPTION	TOTAL EV- READY CCT	DF	TOTAL EV CHARGING POWER (KW)	TOTAL BUILDING LOAD (KW)		
BUILDING ONLY						
Building Only			_	133		
RESIDENTIAL EV CHARGING OPTIONS						
C1. Dedicated circuits on 40A, 100% EV Read	8	100%	53	186		
C2. 4-share on 40A, 100% EV Ready	2	100%	13	146		
C3. 8-share on 70A, 1000% EV Ready	1	100%	12	144		

Appendix B: Single line diagrams






CITY OF CALGARY & CITY OF EDMONTON
EV CHARGING COSTING STUDY

drawing title HIGH RISE BASELINE

designed		scale	date	
	JC	AS NOTED	12-08-2021	
drawn	JC	project no. 2-21-418		
checked	RB	drawing no.		rev.
approved	RB	E-00		1






EV CHARGING COSTING STUDY

drawing title **HIGH RISE** C1. DEDICATED CIRCUITS ON 40A, 100% EV READY

designed		scale	date 12-08-2021	
	JC	AS NOTED		
drawn	JC	project no. 2-21-418		
checked	RB	drawing no. rev		rev.
approved	RB			1






EV CHARGING COSTING STUDY

drawing title

HIGH RISE C2. 4-SHARE ON 40A, 100% EV READY

approved	RB	E-02 ₁		1
checked	RB	drawing no. rev.		rev.
drawn	JC	project no. 2-21-	-418	
designed	JC	scale AS NOTED	date 12-08-2021	






CITY OF CALGARY & CITY OF EDMONTON EV CHARGING COSTING STUDY

drawing title

HIGH RISE C3. 10-SHARE ON 80A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	12-08-2021	
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved	RB	E-03		1






HIGH RISE drawing title

C4. 4-SHARE ON 40A, 100% EV READY /W SERVICE MONITORING

designed		scale	date	
	JC	AS NOTED	12-08-2021	
drawn	JC	project no. 2-21-418		
checked	RB	drawing no.		rev.
approved	RB			1






CITY OF CALGARY & CITY OF EDMONTON
EV CHARGING COSTING STUDY

drawing title MID RISE BASELINE

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved	RB	E-10		1






EV CHARGING COSTING STUDY

drawing title

MID RISE C1. DEDICATED CIRCUITS ON 40A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn	JC	project no. 2-21-	418	·
checked	RB	drawing no.		rev.
approved	RB	E-11		1



Designing A Better Tomorrow

505 Burrard Street. Suite 950, Vascouver, BC V77, 1M4

604.569.6500 | www.aeeengt.com


CALGARY | VANCOUVER | WICTORIA

CITY OF CALGARY & CITY OF EDMONTON EV CHARGING COSTING STUDY

drawing title

MID RISE C2. 4-SHARE ON 40A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved	RB	E-12		1




C) CABLE SIZING BASED ON COPPER CABLES

Designing A Better Tomorrow 505 Burrard Street, Silker 950, Vancouver, BC V7X 11M4 CALGARY | VANCOUVER | VICTORIA

CITY OF CALGARY & CITY OF EDMONTON EV CHARGING COSTING STUDY

drawing title MID RISE
C3. 10-SHARE ON 80A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved	RB	E-13		1






CITY OF CALGARY & CITY OF EDMONTON
EV CHARGING COSTING STUDY

drawing title TOWNHOUSE BASELINE

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved		E-20		1
	RB			1



KEYNOTES:

consultant

- 1. 225A, 208Y/120V 18 CCT PANELBOARD
- 2. 1 EV STALL PER 40 A, 208 V BRANCH CIRCUIT

GENERAL NOTES:


A) CABLE SIZING BASED ON COPPER CABLES

Designing A Better Tomorrow

CITY OF CALGARY & CITY OF EDMONTON EV CHARGING COSTING STUDY

TOWNHOUSE
C1. DEDICATED CIRCUITS ON 40A, 100% EV READY

designed		scale	date	
	JC	AS NOTED		8-2021
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved	RB	E-21		1



GENERAL NOTES:

KEYNOTES:

A) CABLE SIZING BASED ON COPPER CABLES


consultant



roject	CITY OF CALGARY & CITY OF EDMONTON
	EV CHARGING COSTING STUDY

drawing title **TOWNHOUSE** C2. 4-SHARE ON 40A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn		project no.	440	
	JC	2-21-	418	
checked	RB	drawing no.		rev.
	110	F-22		
approved	RB	E-22		1



GENERAL NOTES:

CIRCUIT

KEYNOTES:

CABLE SIZING BASED ON COPPER CABLES

drawing title


consultant Designing A Better Tomorrow


CITY OF CALGARY & CITY OF EDMONTON **EV CHARGING COSTING STUDY**

TOWNHOUSE C3. 8-SHARE ON 70A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	12-0	8-2021
drawn	JC	project no. 2-21-	418	
checked	RB	drawing no.		rev.
approved	RB	E-23		1

Appendix C: Parking layout drawings












drawing title

CITIES OF CALGARY & EDMONTON EV COSTING STUDY	
HIGH RISE P2 C2. 4-SHARE ON 40A, 100% EV READY	

N 28, 2022
rev.
2
-










project	CITIES OF CALGARY & EDMONTON
	EV COSTING STUDY


HIGH RISE P2 C3. 10-SHARE ON 80A, 100% EV READY

designed		scale	date	
	JC	AS NOTED	JAN	1 28, 2022
drawn		project no.		
	JC	2-21-418		
checked		drawing no.		rev.
	RB	E 404 D0		
approved		E-104-P2		2
	RB			










LEGEND OF SYMBOLS





DISTRIBUTION PANEL





project	CITIES OF CALGARY AND EDMONTON EV COSTING STUDY
drawing title	TOWNHOUSE C1. DEDICATED ON 40A, 100% EV READY


designed		scale		date	
	JC		AS NOTED	JAN 2	8, 2022
drawn		project no.			
	JC		2-21-418		
checked	RB	drawing no.			rev.
	KB		F 200		
approved	RB		E-302		2

LEGEND OF SYMBOLS

JUNCTION BOXEVSE



DISTRIBUTION PANEL





project	CITIES OF CALGARY AND EDMONTON EV COSTING STUDY
drawing title	TOWNHOUSE C2. 4-SHARE ON 40A, 100% EV READY


designed		scale		date	
	JC		AS NOTED	JAN 2	28, 2022
drawn		project no.			
	JC		2-21-418		
checked		drawing no.			rev.
	RB		E 202		
approved	RB		E-303		1

LEGEND OF SYMBOLS

JUNCTION BOX

▼ EVSE

DISTRIBUTION PANEL





project	CITIES OF CALGARY AND EDMONTON EV COSTING STUDY	
drawing title	TOWNHOUSE C1. 4-SHARE ON 40A, 100% EV READY	

designed		scale		date	
	JC		AS NOTED	JAN	28, 2022
drawn		project no.			
	JC		2-21-418		
checked		drawing no.			rev.
	RB		E 204		
approved	RB		E-304		2

Appendix D: Costing estimates

HIGH-RISE RESIDENTIAL 1. Dedicated circuits on 40A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 204

Total Level 2 Circuits: 204

Existing max. demand (kVA): 2,364

EVSE max. demand (kVA): 950

Final max. demand (kVA): 3,314

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)
ELECTRIC	CAL INFRASTRUCTURE			
1 25kV	splice	8,500	1	8,500
2 25kV	loadbreak	65,000	1	65,000
3 25kV	:600Y/347V, 1500 kVA transformer	100,815	1	100,815
4 Circu	it breaker for EV feed distribution board (2000A)	56,226	1	56,226
5 EV fe	ed distribution board (2000A)	13,711	1	13,711
6 Prima	ary circuit breaker for EV distribution board (1000A)	23,296	2	46,593
7 600V	: 208Y/120V, 750 kVA transformer	26,450	2	52,899
8 EV di	stribution board (3000A)	18,165	2	36,330
9 Circu	it breaker for EV panelboard (400A)	6,405	13	83,265
10 Cabli	ng from EV distribution board to panelboard (2 sets of 4#3/0)	77	906	70,049
11 Cabli	ng from EV distribution board to panelboard (2 sets of 4#4/0)	111	936	103,920
12 Cond	uit from EV distribution board to panelboard (2 sets of 53mm (2"))	33	906	29,718
13 Cond	uit from EV distribution board to panelboard (2 sets of 63mm (2 1/2"))	45	936	42,100
	anelboard breaker (40A)	220	204	44,830
15 400A	MLO, 208Y/120V, 42 cct panelboard	2,499	13	32,484
16 Cabli	ng from panelboard to EVSE (2#8)	4	17352	77,010
18 Cond	luit from panelboard to EVSE (21mm (3/4"))	8	17352	138,946
19 Comr	munication system	54,264	1	54,264
20 Utility		3,990	1	3,990

3 25,50 3 195,00 3 302,44 3 168,67 5 68,55	0 -5 '9
3 195,00 3 302,44 3 168,67 5 68,55	0 -5 '9
3 195,00 3 302,44 3 168,67 5 68,55	0 -5 '9
3 302,44 3 168,67 5 68,55	5
3 168,67 5 68,55	9
5 68,55	
	1
······································	+
3 139,77	8
3 158,69	7
5 181,6	51
3 249,79	25
2 140,09	8
2 207,84	11
5 148,59	
5 210,50	
2 89,66	
3 97,4	
2 154,02	
5 694,72	
3 162,79	
2 7,98	

 Cost (\$)
 1,060,650
 3,403,759

 Cost (\$ per stall)
 5,199
 16,685

HIGH-RISE RESIDENTIAL 2. 4-share on 40A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 204
Total Level 2 Circuits: 96
Existing max. demand (kVA): 2,364
EVSE max. demand (kVA): 639
Final max. demand (kVA): 3,003

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELE	CTRICAL INFRASTRUCTURE					
1	Increased rating of 25kV:600Y/347V main transformer (2500kVA to 3000kVA)	10,676	1	10,676	8	80,066
2	Increased rating of circuit breaker for main switchboard (2500A to 3000A)	11,869	1	11,869	3	35,608
3	Increased rating of main distribution board (2500A to 3000A)	3,712	1	3,712	8	27,840
4	600V : 208Y/120V, 500 kVA transformer	16,731	1	16,731	3	50,193
5	Circuit breaker for EV distribution board (600A)	14,534	1	14,534	3	43,602
6	EV distribution board (2000A)	13,711	1	13,711	5	68,554
7	Circuit breaker for EV panelboard (400A)	6,405	3	19,215	3	57,645
8	Circuit breaker for EV panelboard (200A)	3,753	1	3,753	3	11,260
9	Cabling from EV distribution board to panelboard (4#3/0)	39	118	4,552	2	9,104
10	Cabling from EV distribution board to panelboard (2 sets of 4#3/0)	77	376	29,036	2	58,072
11	Conduit from EV distribution board to panelboard (53mm (2"))	16	118	1,931	5	9,656
12	Conduit from EV distribution board to panelboard (2 sets of 53mm (2"))	33	376	12,318	5	61,592
13	EV panelboard breaker (40A)	220	53	11,647	2	23,294
14	400A MLO, 208Y/120V, 42 cct panelboard	2,499	3	7,496	3	22,489
15	225A MLO, 208Y/120V, 42 cct panelboard	1,739	1	1,739	3	5,217
16	Cabling from panelboard to EVSE (2#8)	4	643	2,854	2	5,708
17	Cabling from panelboard to EVSE (2#6)	7	4245	27,759	2	55,517
18	Cabling from panelboard to EVSE (2#4)	9	3537	32,911	2	65,822
19	Conduit from panelboard to EVSE (21mm (3/4"))	8	643	5,149	5	25,745
20	Conduit from panelboard to EVSE (27mm (1"))	10	7782	77,246	5	386,232

21 Communication system	54,264	1	54,264	3	162,792
22 Utility meter	3,990	1	3,990	2	7,980
Cost (\$)			367,094		1,273,989
Cost (\$ per stall)			1,799		6,245

1,008,951

HIGH-RISE RESIDENTIAL 3. 10-share on 80A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 204
Total Level 2 Circuits: 21
Existing max. demand (kVA): 2,364
EVSE max. demand (kVA): 280
Final max. demand (kVA): 2,644

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTI	RICAL INFRASTRUCTURE					
1 Inc	reased rating of 25kV:600Y/347V main transformer (2500kVA to 3000kVA)	10,676	1	10,676	8	80,066
2 Inc	reased rating of circuit breaker for main switchboard (2500A to 3000A)	11,869	1	11,869	3	35,608
3 Inc	reased rating of main distribution board (2500A to 3000A)	3,712	1	3,712	3	11,136
4 600	DV : 208Y/120V, 300 kVA transformer	11,913	1	11,913	8	89,348
5 Circ	cuit breaker for EV distribution board (400A)	6,405	1	6,405	3	19,215
6 EV	distribution board (1200A)	12,342	1	12,342	5	61,711
7 Circ	cuit breaker for EV panelboard (400A)	6,405	3	19,215	3	57,645
8 Cal	oling from EV distribution board to panelboard (2 sets of 4#3/0)	77	338	26,120	2	52,240
9 Cor	nduit from EV distribution board to panelboard (2 sets of 53mm (2"))	33	338	11,081	5	55,406
10 EV	panelboard breaker (80A)	441	21	9,257	2	18,514
11 400	DA MLO, 208Y/120V, 42 cct panelboard	2,499	3	7,496	3	22,489
12 Cal	oling from panelboard to EVSE (2#4)	9	696	6,472	2	12,945
13 Cal	oling from panelboard to EVSE (2#3)	12	1365	15,979	2	31,959
14 Cal	oling from panelboard to EVSE (2#2)	14	1788	24,243	2	48,486
15 Cor	nduit from panelboard to EVSE (35mm (1 1/4"))	13	3848	48,282	5	241,412
16 Cor	mmunication system	54,264	1	54,264	3	162,792
17 Uti	lity meter	3,990	1	3,990	2	7,980

283,317

Cost (\$)

Cost (\$ per stall) 1,389 4,946

HIGH-RISE RESIDENTIAL

4. 4-share on 40A, 100% EV Ready w/ Service Monitoring

Total Level 2 EV-Ready Stalls: 204
Total Level 2 Circuits: 52
Existing max. demand (kVA): 2,364
EVSE max. demand (kVA): 346
Final max. demand (kVA): 2,364

No. DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICAL INFRASTRUCTURE					
1 Circuit breaker for EV distribution board (600A)	14,534	1	14,534	3	43,602
2 (00) (200) (120) (500 b) (4 to a set one of	1/ 701	1	16.731	3	50,193
3 EV distribution board (2000A)	13,711	1	13,711	5	68,554
4 Circuit breaker for EV panelboard (400A)	6,405	3	19,215	3	57,645
5 Circuit breaker for EV panelboard (200A)	3,753	1	3,753	3	11,260
6 Cabling from EV distribution board to panelboard (4#3/0)	39	118	4,552	2	9,104
7 Cabling from EV distribution board to panelboard (2 sets of 4#3/0)	77	376	29,036	2	58,072
8 Conduit from EV distribution board to panelboard (53mm (2"))	16	118	1,931	5	9,656
9 Conduit from EV distribution board to panelboard (2 sets of 53mm (2"))	33	376	12,318	5	61,592
10 EV panelboard breaker (40A)	220	53	11,647	2	23,294
11 400A MLO, 208Y/120V, 42 cct panelboard	2 4 9 9	3	7,496	3	22,489
12 225A MLO, 208Y/120V, 42 cct panelboard	1,739	1	1,739	3	5,217
16 Cabling from panelboard to EVSE (2#8)	4	643	2,854	2	5,708
17 Cabling from panelboard to EVSE (2#6)	7	4843	31,663	2	63,326
18. Cabling from panelboard to EVSE (2#4)	Q	3537	32,911	2	65,822
19 Conduit from panelboard to EVSE (21mm (3/4"))	8	643	5,149	5	25,745
20 Conduit from panelboard to EVSE (27mm (1"))	10	8379	83,173	5	415,867
16 Communication system	54.264	1	54,264	3	162,792
17 Utility meter	3,990	1	3,990	2	7,980
18 EVEMS	15,000	1	15,000	3	45,000

Cost (\$) 336,134 1,124,316

Cost (\$ per stall) 5,511

MID-RISE RESIDENTIAL 1. Dedicated circuits on 40A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 169
Total Level 2 Circuits: 169
Existing max. demand (kVA): 1,522
EVSE max. demand (kVA): 787
Final max. demand (kVA): 2,309

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICAL INFRAST	FRUCTURE					
1 Increased rating o	of 25kV : 600Y/347V main transformer (2000kVA to 3000kVA)	10,676	1	10,676	8	80,066
2 Increased rating of	of main circuit breaker (2000A to 3000A)	9.845	1	9,845	3	29,536
3 Increase rating of	main distribution board (2000A to 3000A)	3,712	1	3,712	8	27,840
4 Primary circuit br	eaker for EV feed (1000A)	14,711	2	29,421	3	88,264
5 600V: 208Y/120V,	750 kVA transformer	26,450	2	52,899	8	396,743
6 EV distribution bo		18,165	2	36,330	5	181,651
7 Circuit breaker for	r EV panelboard (400A)	6,405	11	70,455	3	211,365
8 EV panelboard br		220	169	37,139	2	74,277
9 400A MLO, 208Y/	120V, 42 cct panelboard	2,499	11	27,486	3	82,459
10 Cabling from EV o	distribution board to panelboard (2 sets of 4#3/0)	77	119	9,231	2	18,461
11 Cabling from EV o	distribution board to panelboard (2 sets of 4#4/0)	109	1253	136,882	2	273,764
12 Cabling from EV o	distribution board to panelboard (2 sets of 4 250kcmil)	119	1139	135,200	2	270,400
	distribution board to panelboard (2 sets of 53mm (2"))	35	119	4,180	5	20,899
14 Conduit from EV	distribution board to panelboard (2 sets of 63mm (2 1/2"))	45	1253	56,389	5	281,947
15 Conduit from EV	distribution board to panelboard (2 sets of 78mm (3"))	61	1139	69,363	5	346,813
16 Cabling from pan	elboard to EVSE (2#8)	4	13344	59,220	2	118,440
17 Cabling from pan	elboard to EVSE (2#6)	6	4931	30,993	2	61,985
18 Cabling from pan	elboard to EVSE (2#4)	8	4160	33,815	2	67,631
19 Conduit from pan	elboard to EVSE (2#4) nelboard to EVSE (21mm/ (3/4"))	8	13344	106,848	5	534,240
20 Conduit from pan	nelboard to EVSE (27mm/ (1"))	10	9091	90,240	5	451,201
21 Communication s	system	44,954	1	44,954	3	134,862
22 Utility meter		3,990	1	3,990	2	7,980

Appendix D

 Cost (\$)
 1,059,268
 3,760,825

 Cost (\$ per stall)
 6,268
 22,253

MID-RISE RESIDENTIAL 2. 4-share on 40A, 100% EV Ready

Total Level 2 EV-Ready Stalls:169Total Level 2 Circuits:43Existing max. demand (kVA):1,522EVSE max. demand (kVA):286Final max. demand (kVA):1,808

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICAL INFRASTRUCTUR	E					
1 Circuit breaker for EV distri	bution board (400A)	6,405	1	6,405	3	19,215
2 600V : 208Y/120V, 300 kVA	transformer	11,913	1	11,913	3	35,739
3 EV distribution board (1200)A)	12,342	1	12,342	5	61,711
4 Circuit breaker for EV pane	lboard (400A)	6,405	3	19,215	5	96,075
5 Cabling from EV switchboa	ard to panelboard (2 sets of 4#3/0)	77	252	19,450	2	38,901
6 Cabling from EV swithcbox	ard to panelboard (2 sets of 4#4/0)	109	313	34,220	2	68,441
7 Conduit from EV switchbo	ard to panelboard (2 sets of 53mm (2"))	33	252	8,252	5	41,259
8 Conduit from EV switchbo	ard to panelboard (2 sets of 63mm (2 1/2"))	45	313	14,097	5	70,487
9 EV panelboard breaker (40	A)	220	43	9,450	2	18,899
10 400A MLO, 208Y/120V, 42 c	ct panelboard	2,499	3	7,496	3	22,489
11 Cabling from panelboard t	o EVSE (2#8)	4	1596	7,082	2	14,164
12 Cabling from panelboard t	o EVSE (2#6)	6	5168	32,482	2	64,963
13 Conduit from panelboard t	o EVSE (21mm (3/4"))	8	1596	12,778	5	63,890
14 Conduit from panelboard t	o EVSE (27mm (1"))	8	5168	41,382	5	206,908
15 Communication system		44,954	1	44,954	3	134,862
16 Utility meter		3,990	1	3,990	2	7,980
Cost (\$)				285,508		965.982
Cost (\$ per stall)				1,689		5,716

MID-RISE RESIDENTIAL 3. 10-share on 80A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 169
Total Level 2 Circuits: 17
Existing max. demand (kVA): 1,522
EVSE max. demand (kVA): 226
Final max. demand (kVA): 1,748

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICAL INFRA	ASTRUCTURE					
1 Circuit breake	r for EV distribution board (300A)	6,405	1	6,405	3	19,215
2 600V: 208Y/12	OV, 225 kVA transformer	9,496	1	9,496	3	28,487
3 EV distribution	n board (800A)	11,288	1	11,288	5	56,438
4 Circuit breake	r for EV panelboard (400A)	6,405	2	12,810	3	38,430
5 Cabling from s	switchboard to panelboard (2 sets of 4#3/0)	77	30	2,308	2	4,615
6 Cabling from E	EV swithcboard to panelboard (2 sets of 4#4/0)	109	313	34,220	2	68,441
7 Conduit from	EV switchboard to panelboard (2 sets of 53mm (2"))	33	30	979	5	4,895
8 Conduit from	EV switchboard to panelboard (2 sets of 63mm (2 1/2"))	45	313	14,097	5	70,487
9 EV panelboard	d breaker (80A)	441	17	7,494	2	14,988
10 400A MLO, 20	8Y/120V, 42 cct panelboard	2,499	2	4,998	3	14,993
11 Cabling from p	oanelboard to EVSE (2#3)	10	3117	30,738	2	61,477
12 Conduit from	panelboard to EVSE (27mm (1"))	10	3117	30,936	5	154,680
13 Communication	on system	44,954	1	44,954	3	134,862
14 Utility meter		3,990	1	3,990	2	7,980
Cost (\$)				214,713		679,988
Cost (\$ per sta				1,270		4,024

TOWNHOUSE 1. Dedicated 40A, 100% FV Ready

Total Level 2 EV-Ready Stalls:8Total Level 2 Circuits:8Existing max. demand (kVA):133EVSE max. demand (kVA):53Final max. demand (kVA):186

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICA	AL INFRASTRUCTURE					
1 Increas	ised rating of 25kV : 208Y/120V main transformer (150kVA to 225kVA)	2,261	1	2,261	8	16,954
2 Increas	sed rating of main circuit breaker (450A to 800A)	5,450	1	5,450	3	16,350
3 Increas	sed rating of main distribution board (450A to 800A)	1,409	1	1,409	3	4,227
4 Primai	ry circuit breaker for EV feed (225A)	3,677	1	3,677	3	11,032
	ng from distribution board (4#3/0)	40	16	649	2	1,298
6 Condu	uit fromdistribution board (53mm (2"))	16	16	269	5	1,345
7 Circuit	t breaker for EV panelboard (40A)	220	8	1,758	2	3,516
8 225A N	MLO, 208Y/120V, 18 cct panelboard	3,364	1	3,364	3	10,093
	ig from panelboard to EVSE (2#8)	2	292	598	2	1,197
10 Condu	uit from panelboard to EVSE (21mm (3/4"))	8	292	2,338	5	11,690
11 Comm	nunication system	2,128	1	2,128	3	6,384
12 Utility	meter	3,990	1	3,990	2	7,980
Cost (\$	\$)			27,892		67,132
Cost (\$	\$ per stall)			3,486		8,391

TOWNHOUSE 2. 4 Share on 40A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 8

Total Level 2 Circuits: 2

Existing max. demand (kVA): 133

EVSE max. demand (kVA): 0

Final max. demand (kVA): 133

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICAL INFRA	STRUCTURE					
1 Primary circuit	breaker for EV feed (100A)	1,731	1	1,731	3	5,193
	istribution board (4#1)	25	16	410	2	819
3 Conduit fromdi	stribution board 53mm (2"))	16	16	269	5	1,345
4 Circuit breaker	for EV panelboard (40A)	220	2	440	2	879
5 125A MLO, 208Y	//120V, 18 cct panelboard	3,364	1	3,364	3	10,093
6 Cabling from pa	anelboard to EVSE (2#8)	4	110	486	2	973
7 Conduit from page	anelboard to EVSE (21mm (3/4"))	8	110	877	5	4,387
8 Communication		2,128	1	2,128	3	6,384
9 Utility meter		3,990	1	3,990	2	7,980
Cost (\$)				13,695		30,696
Cost (\$ per stall))			1,712		3,837

TOWNHOUSE 3. 8 Share on 70A, 100% EV Ready

Total Level 2 EV-Ready Stalls: 8

Total Level 2 Circuits: 2


Existing max. demand (kVA): 133


EVSE max. demand (kVA): 0


Final max. demand (kVA): 133

No.	DESCRIPTION	UNIT COST (\$ or \$/ft)	QTY (# or ft)	COST (\$)	MULTIPLIER FOR LATER COSTS	LATER COST (\$)
ELECTRICAL INFRA	STRUCTURE					
	breaker for EV feed (100A)	1,731	1	1,731	3	5,193
	istribution board (4#1)	25	16	410	2	819
3 Conduit fromd	istribution board 53mm (2"))	16	16	269	5	1,345
4 125A MLO, 208\	//120V, 18 cct panelboard	3,364	1	3,364	3	10,093
5 Circuit breaker	for EV panelboard (70A)	441	1	441	2	882
6 Cabling from p	anelboard to EVSE (2#8)	4	73	324	2	648
7 Conduit from p	panelboard to EVSE (21mm (3/4"))	8	73	585	5	2,923
8 Communicatio		2,128	1	2,128	3	6,384
9 Utility meter		3,990	1	3,990	2	7,980
Cost (\$)				13,241		18,816
Cost (\$ per stal	I)			1,655		2,352

Appendix E: Cost categories







consultant

KEYNOTES:

CIRCUIT



CITY OF CALGARY & CITY OF EDMONTON **EV CHARGING COSTING STUDY**

drawing title **TOWNHOUSE** C1. DEDICATED CIRCUITS ON 40A, 100% EV READY

designed	scale	date	
JC	AS NOTED		
drawn JC	project no. 2-21-	418	
checked	drawing no.		rev.
approved	E-21		۸
арргочец			Α