



# City of Calgary Glenmore Water Treatment Plant Summary

January 1, 2021 to December 31 2021

PARAMETER	UNITS	Glenmore Treated Water (Entering the Distribution System)			Maximum Acceptable Concentration or Guideline <sup>1</sup>	Common Source
		Minimum	Maximum	Average		
Alkalinity, Total	mg/L as CaCO <sub>3</sub>	96	173	144	No Guidelines	Erosion of natural deposits in watershed.
Aluminum	mg/L	0.018	0.338	0.096	0.100 (O) (Annual Average)	Water treatment process
Ammonia	mg/L as N	<0.05	0.060	<0.05	No Guidelines	Naturally occurring; released from agricultural or industrial wastes.
Antimony	mg/L		<0.0005		0.006	Erosion of natural deposits in watershed
Arsenic	mg/L		<0.0005		0.010	Erosion of natural deposits in watershed
Atrazine + metabolites	mg/L		<0.001		0.005	Leaching and/or runoff from agricultural or rural use
Azinphos - methyl	mg/L		<0.001		0.02	Leaching and/or runoff from agricultural or rural use
Barium	mg/L	0.053	0.080	0.069	2.0	Erosion of natural deposits in watershed
Benzene	mg/L		<0.0005		0.005	Releases or spills from industrial use
Benzo[a]pyrene	mg/L		<0.000005		0.00004	Distribution System materials
Beryllium	mg/L		<0.0005		No Guidelines	Contamination from ceramic applications and manufacturing of aerospace, electronics and mechanical industries
Bicarbonate	mg/L as CaCO <sub>3</sub>	96	173	144	No Guidelines	Erosion of natural deposits in watershed
Boron	mg/L	0.006	0.009	0.008	5	Naturally occurring; leaching or runoff from industrial use
Bromate	mg/L		<0.0095		0.01	Possible contamination in hypochlorite solution
Bromoxynil	mg/L		<0.0001		0.005	Leaching and/or runoff from agricultural or rural use
Cadmium	mg/L		<0.0005		0.007	Erosion of natural deposits in watershed
Calcium	mg/L	47	71	57	No Guidelines	Erosion of natural deposits in watershed
Carbaryl	mg/L		<0.002		0.09	Leaching and/or runoff from agricultural or rural use
Carbofuran	mg/L		<0.0005		0.09	Leaching and/or runoff from agricultural or rural use
Carbonate	mg/L as CaCO <sub>3</sub>		<20		No Guidelines	Erosion of natural deposits in watershed
Carbon Tetrachloride	mg/L		<0.0005		0.002	Industrial effluents and leaching from hazardous waste sites
Chloramines, Total	mg/L	<0.09	0.11	<0.09	No Guidelines	Formed in the presence of both chlorine and ammonia
Chlorate	mg/L		<0.050		1	Possible contamination in hypochlorite solution
γ-Chlordane	mg/L		<0.0001		No Guidelines	Leaching and/or runoff from agricultural or rural use
Chloride	mg/L	5.8	18.9	10.3	250 (A)	Naturally occurring, dissolved salt deposits, highway salt
Chlorine, free	mg/L	0.85	1.35	1.08	No Guidelines	Water treatment process
Chlorite	mg/L		<0.050		1	Possible contamination in hypochlorite solution, water treatment
Chlorpyrifos	mg/L		<0.001		0.09	Leaching and/or runoff from agricultural or rural use
Chromium	mg/L	<0.0005	0.0006	<0.0005	0.05	Erosion of natural deposits in watershed
Cobalt	mg/L		<0.0005		No Guidelines	Erosion of natural deposits in watershed.
Coliforms, <i>E.coli</i>	MPN/100mL		<1		0	Domestic animals, wildlife and human waste.
Coliforms, Total	MPN/100mL		<1		0	Soil, domestic animals and wildlife.
Color	TCU		<2.0		15 (A)	Erosion of natural deposits in watershed.
Conductivity at 25°C	uS/cm	354	529	439	No Guidelines	Leaching and/or runoff from agricultural or rural use
Copper	mg/L	<0.0005	0.0015	<0.0005	2 1 (A)	Erosion of natural deposits in watershed.
Cryptosporidium	oocysts/100L	Not Tested			No Guideline Raw Water	Domestic animals, wildlife and human waste.
Cryptosporidium, Min. Log Reduction Ratio <sup>3</sup>	no units	1.33			Treatment Goal >=1	Domestic animals, wildlife and human waste.
Cyanazine	mg/L		<0.001		No Guidelines	Leaching and/or runoff from agricultural or rural use
Cyanide	mg/L		<0.0020		0.2	Industrial and mining effluents; Release from organic compounds.
Cyanobacterial toxins – total microcystin	mg/L		<0.0002		0.0015	Naturally occurring; released from blooms of blue-green algae
Diazinon	mg/L		<0.001		0.02	Run off from agricultural or other uses.
Dicamba	mg/L		<0.0002		0.11	Leaching and/or runoff from agricultural or rural use
1,2-Dichlorobenzene	mg/L		<0.0005		0.2 0.003(A)	Releases or spills from industrial use
1,4-Dichlorobenzene	mg/L		<0.0005		0.005 0.001(A)	Releases or spills from industrial use
2,4-DDT	mg/L		<0.0001		No Guidelines	Leaching and/or runoff from agricultural or rural use
4,4'-DDT	mg/L		<0.0001		No Guidelines	Leaching and/or runoff from agricultural or rural use
1,1-Dichloroethylene	mg/L		<0.0005		0.014	Releases or spills from industrial use
1,2-Dichloroethane	mg/L		<0.0005		0.005	Releases or spills from industrial use



# City of Calgary Glenmore Water Treatment Plant Summary

January 1, 2021 to December 31 2021

PARAMETER	UNITS	Glenmore Treated Water (Entering the Distribution System)			Maximum Acceptable Concentration or Guideline <sup>1</sup>	Common Source
		Minimum	Maximum	Average		
Dichloromethane	mg/L	<0.0005			0.05	Industrial and municipal wastewater discharges
2,4-Dichlorophenol	mg/L	<0.0005			0.9 0.0003(A)	By-product of chlorination.
2,4-D	mg/L	<0.0001			0.1	Leaching and/or runoff from use as a weed controller
Diclofop-methyl	mg/L	<0.0001			0.009	Leaching and/or runoff from use as a weed controller
Dimethoate	mg/L	<0.001			0.02	Leaching and/or runoff from agricultural or rural use
Diquat	mg/L	<0.007			0.05	Leaching and/or runoff from agricultural or rural use
Diuron	mg/L	<0.00005			0.15	Leaching and/or runoff from use in controlling vegetation
Endrin	mg/L	<0.0001			No Guidelines	Leaching and/or runoff from agricultural or rural use
Ethylbenzene	mg/L	<0.0005			0.14 0.0016 (A)	Emissions, effluents or spills from petroleum and chemical industries
Extractable Hydrocarbons	mg/L	<0.01			No Guidelines	Releases or spills from industrial use
Fluoride	mg/L	0.10	0.28	0.22	1.5	Erosion of natural deposits in watershed. <sup>2</sup>
Giardia	cysts/100L	Not Tested			No Guideline Raw Water	Domestic animals, wildlife and human waste.
Giardia, Min. Log Reduction Ratio <sup>3</sup>	no units	1.76	7.54	3.65	Treatment Goal >=1	Domestic animals, wildlife and human waste.
Glyphosate	mg/L	<0.005			0.28	Leaching and/or runoff from use as a weed controller.
Gross Alpha	Bq/L	<0.22			0.5	Naturally occurring; emissions from nuclear reactors
Gross Beta	Bq/L	<0.09	0.11	<0.09	1.0	Naturally occurring; emissions from nuclear reactors
Haloacetic Acids, Total	mg/L	0.0053	0.0323	0.0159	0.08 (Annual Average)	By-product of chlorination.
Hardness	mg/L as CaCO <sub>3</sub>	174	263	217	No Guidelines	Erosion of natural deposits in watershed.
Heptachlor + heptachlor epoxide	mg/L	<0.0001			No Guidelines	Leaching and/or runoff from agricultural or rural use
Iron	mg/L	<0.010	0.044	<0.010	0.3 (A)	Erosion of natural deposits in watershed.
Lead	mg/L	<0.0005			0.005	Leaching from plumbing (pipes, solders, brass fittings, and lead service lines)
Lindane	mg/L	<0.0001			No Guidelines	Leaching and/or runoff from agricultural or rural use
Lithium	mg/L	0.0032	0.0051	0.0043	No Guidelines	Releases or spills from industrial use
Magnesium	mg/L	13.2	22.2	17.8	No Guidelines	Erosion of natural deposits in watershed.
Malathion	mg/L	<0.001			0.19	Leaching and/or runoff from agricultural or rural use
Manganese	mg/L	<0.0005	0.0046	<0.0005	0.12 0.02 (A)	Erosion of natural deposits in watershed.
MCPA (2-methyl-4-chlorophenoxyacetic acid)	mg/L	<0.00002			0.35	Leaching and/or runoff from agricultural and other uses
MCPP (methylchlorophenoxy propionic acid)	mg/L	<0.00005			0.015 (A)	Leaching and/or runoff from agricultural and other uses
Mercury	mg/L	<0.0000019			0.001	Erosion of natural deposits in watershed
Methyl parathion	mg/L	<0.001			No Guidelines	Leaching and/or runoff from agricultural or rural use
Methoxychlor	mg/L	<0.0001			No Guidelines	Leaching and/or runoff from agricultural or rural use
Metolachlor	mg/L	<0.001			0.05	Leaching and/or runoff from agricultural and other uses
Metribuzin	mg/L	<0.001			0.08	Leaching and/or runoff from agricultural or rural use
Mirex	mg/L	<0.0001			No Guidelines	Leaching and/or runoff from agricultural or rural use
Molybdenum	mg/L	0.0005	0.0008	0.0007	No Guidelines	Leaching and/or runoff from industrial, agricultural and other uses
Monochlorobenzene	mg/L	<0.0005			0.08 0.03(A)	Releases or spills from industrial effluents
MTBE (methyl tertiary-butyl ether)	mg/L	<0.0005			0.015 (A)	Spills from gasoline refineries, filling stations and gasoline powered boats; seepage into groundwater from leaking storage tanks
Nickel	mg/L	<0.0005	0.0007	<0.0005	No Guidelines	Leaching from plumbing (pipes, solders, and brass fittings)
Nitrate	mg/L as N	<0.005	0.180	0.059	10	Erosion of natural deposits in watershed
Nitrite	mg/L as N	<0.005	0.005	<0.005	1	Erosion of natural deposits in watershed
Nitrioltriacetic acid (NTA)	mg/L	<0.2			0.4	Sewage contamination
N-Nitrosodimethylamine (NDMA)	mg/L	<0.0000021			0.00004	By-product of chlorination; industrial and sewage treatment plant
Nitrogen, total (TKN)	mg/L	<0.10	0.28	<0.10	No Guidelines	Erosion of natural deposits in watershed
Odour	Scale = 0-12	8.0	11.0	9.8	Inoffensive	Biological, industrial, or treatment disinfection sources
Paraquat	mg/L	<0.001			0.01	Leaching and/or runoff from agricultural and other uses
Parathion	mg/L	<0.001			0.05	Leaching and/or runoff from agricultural or rural use



# City of Calgary Glenmore Water Treatment Plant Summary

January 1, 2021 to December 31 2021

PARAMETER	UNITS	Glenmore Treated Water (Entering the Distribution System)			Maximum Acceptable Concentration or Guideline <sup>1</sup>	Common Source
		Minimum	Maximum	Average		
Pentachlorophenol	mg/L	<0.0001			0.06 0.03 (A)	By-product of chlorination
Perfluorooctane Sulfonate (PFOS)	mg/L	<0.00001			0.0006	Synthetic chemical used in consumer products and fire-fighting foams for their water and oil repellent properties.
Perfluorooctanoic Acid (PFOA)	mg/L	<0.00001			0.0002	Synthetic chemical used in consumer products and fire-fighting foams for their water and oil repellent properties.
Pesticides, total	mg/L	<0.01			No Guidelines	Leaching and/or runoff from agricultural or rural use
pH	pH units	7.2	8.0	7.8	7.0 - 10.5 (O)	Influenced by the dissolved minerals in the water, temperature and water treatment processes.
Phorate	mg/L	<0.0005			0.002	Leaching and/or runoff from agricultural and other uses
Phosphorus, Total	mg/L	0.001	0.006	0.003	No Guidelines	Leaching and/or runoff from agricultural and other uses
Phthalate Esters	mg/L	<0.01			No Guidelines	Industrial effluents or spills
Picloram	mg/L	<0.0002			0.19	Leaching and/or runoff from agricultural and other uses
Potassium	mg/L	0.6	1.1	0.9	No Guidelines	Erosion of natural deposits in watershed.
Polycyclic Aromatic Hydrocarbons <sup>3</sup> (PAH)	mg/L	<0.0001			No Guidelines	Industrial sources
Selenium	mg/L	<0.0005	0.0008	<0.0005	0.05	Naturally occurring (erosion and weathering of rocks and soils) and release from coal ash from coal-fired power plants and mining, refining of copper and other metals
Silicon, dissolved	mg/L	1.19	2.11	1.80	No Guidelines	Erosion of natural deposits in watershed.
Silver	mg/L	<0.001			No Guidelines	Naturally occurring (erosion and weathering of rocks and soils)
Simazine	mg/L	<0.001			0.01	Leaching and/or runoff from agricultural and other uses
Sodium	mg/L	5.2	13.6	7.9	200 (A)	Erosion of natural deposits in watershed.
Strontium	mg/L	0.295	0.471	0.393	7.0	Erosion of natural deposits in watershed.
Sulphate	mg/L	54	83	69	500 (A)	Erosion of natural deposits in watershed.
Sulphide	mg/L as H <sub>2</sub> S	<0.0018			0.05 (A)	Can occur in the distribution system from the reduction of sulphates by sulphate-reducing bacteria; industrial wastes
Taste	mg/L	Not Tested			Inoffensive (A)	Biological or industrial sources
Temperature	°C	4.6	23.5	12.0	15 (A)	Surface water temperature.
Terbufos	mg/L	<0.0005			0.001	Leaching and/or runoff from agricultural and other uses
Tetrachloroethylene	mg/L	<0.0005			0.01	Industrial effluents or spills
2,3,4,6-Tetrachlorophenol	mg/L	<0.0005			0.1	By-product of chlorination; industrial effluents and use of pesticides
Thallium	mg/L	<0.0005			No Guidelines	Erosion of natural deposits in watershed.
Tin	mg/L	<0.0005			No Guidelines	Industrial effluents or spills
Titanium	mg/L	<0.0005			No Guidelines	Industrial effluents or spills
Toluene	mg/L	<0.0005			0.06 0.024(A)	Emissions, effluents or spills from petroleum and chemical industries
Total Dissolved Solids	mg/L	219	315	260	500 (A)	Erosion of natural deposits in watershed.
Total Organic Carbon	mg/L	0.6	2.3	1.1	No Guidelines	Erosion of natural deposits in watershed.
Triallate	mg/L	<0.001			No Guidelines	Leaching and/or runoff from agricultural and other uses
Trichloroethylene	mg/L	<0.0005			0.005	Industrial effluents and spills from improper disposals
2,4,6-Trichlorophenol	mg/L	<0.0005			0.005 0.002 (A)	By-product of chlorination; industrial effluents and spills
Trifluralin	mg/L	<0.001			0.045	Runoff from agricultural uses
Total Trihalomethanes <sup>3</sup> (TTHMs)	mg/L	0.0066	0.0377	0.0176	0.1 (Annual Average)	By-product of chlorination.
Turbidity	NTU	<0.05	0.08	<0.05	1.0	Suspended particles in solution.
Uranium	mg/L	<0.0005	0.0006	<0.0005	0.02	Industrial effluents or spills
Vanadium	mg/L	<0.0005	0.0006	<0.0005	No Guideline	Naturally occurring (erosion and weathering of rocks and soils)
Vinyl Chloride	mg/L	<0.0005			0.002	Industrial effluents; degradation product from organic solvents in groundwater; leaching from polyvinyl chloride pipes
Virus, Min. Log Reduction Ratio <sup>3</sup>	no units	1.5			Treatment Goal >=1	Domestic animals, wildlife and human waste.
Xylenes, total <sup>3</sup>	mg/L	<0.001			0.09 0.02 (A)	Emissions, effluents or spills from petroleum and chemical industries



# City of Calgary Glenmore Water Treatment Plant Summary

January 1, 2021 to December 31 2021

PARAMETER	UNITS	Glenmore Treated Water (Entering the Distribution System)			Maximum Acceptable Concentration or Guideline <sup>1</sup>	Common Source
		Minimum	Maximum	Average		
Zinc	mg/L	<0.003			5.0 (A)	Erosion of natural deposits in watershed. Leaching may occur from galvanized pipes, hot water tanks and brass fittings.

## Legend

<sup>1</sup> Maximum acceptable concentrations and guidelines as determined by Health Canada and the Alberta Environment and Parks license to operate.

### Information hyperlinks

[Health Canada Guidelines for Canadian Drinking Water Quality, Summary Table](#)

[Health Canada Water Quality - Reports and](#)

[Alberta Environment & Parks](#)

<sup>2</sup> The City of Calgary ceased fluoridation of its drinking water on May 19, 2011.

<sup>3</sup> Calculated parameter based on individual analytes

(O) Operating guidance as determined by Health Canada

(A) Aesthetic Objective as determined by Health Canada

(AEP) Alberta Environment and Parks provincial guidance

< Indicates not detected above the specified value

Bq/L = Becquerel per litre

mg/L = milligrams per litre, or parts per million (ppm)

MPN = Most-Probable Number

NTU = Nephelometric Turbidity Units

TCU = True Colour Units

Giardia/Cryptosporidium 'No Guideline' - Raw water enteric protozoa concentrations are used to determine the treatment goal

Treatment Goal = Calculated log removals are health based treatment goals for enteric protozoa and viruses as determined by Health Canada